



# OLYMPIC VALLEY FIRE DEPARTMENT



## Pre-Inspection Check List

- Street address is visible from the street, contrasts w/background and a minimum of 5 inches in height
- Annual grasses and weeds are 4 inches or less 100 feet from house or to property line
- All pine needles, thin brush and other flammable vegetation have been removed within 100 feet from house or to property line
- The roof of any structure is free of pine needles, leaves or any other dead/dying debris
- All portions of trees within 10 feet of chimneys and/or stovepipe outlets have been removed
- All limbs of trees are a minimum of 6 feet from the ground
- All dead tree limbs adjacent to or overhanging any structure or decks have been removed
- All debris, slash/needle piles, construction debris and flammable storage from under and around structure have been cleared
- The vegetation around firewood storage piles have been cleared to mineral soil
- All brush, limbs, grasses, needles and debris have been removed within 10 feet in all directions from around propane tank
- Installed a 1/8-inch mesh screen spark arrester on chimneys, stovepipes and appliances that burn solid fuels
- Maintained defensible space a minimum of 10 feet from the shoulder of the roadway
- Any hazardous vegetation constituting an extreme fire hazard, as determined by the code official have been removed

Have all the above been checked off? Yes \_\_\_ No\_\_\_

Comments:

---



---



---

**We appreciate your fire prevention efforts. If you have any questions or concerns, please contact Olympic Valley Fire Department by e-mail at: [prevention@olympicvalleyfire.org](mailto:prevention@olympicvalleyfire.org)**  
**Thank you for helping to keep our community fire safe.**