



# OLYMPIC VALLEY PUBLIC SERVICE DISTRICT BOARD REPORT



---

**SUBJECT:** June 2025 Water & Sewer Operations Report      **EXHIBIT:** G-2, 4 Pages  
**AUTHOR:** Nicolas Massetani, Acting Operations Superintendent      **MEETING DATE:** July 29, 2025

---

**RECOMMENDED ACTION:** This report is informational only; no action is requested from the Board.

**DISCUSSION:** This report provides information from the District's management on current projects and activities that are not the subject of a separate report. This report is prepared to provide new information and recent progress only.

## Flow Report – June 2025

Water Production: 13.59 MG  
Comparison: 2.04 MG More than 2024

Sewer Collection: 5.52 MG  
Comparison: 0.57 MG More than 2024

Aquifer Level:	June 30, 2025:	6,187.2'
	June 30, 2024:	6,187.3'
	Highest Recorded:	6,192.0'
	Lowest Recorded:	6,174.0'

Creek Bed Elevation, Well 2: 6,186.9'

Precipitation:	June 2025:	0.34"
	Season to date total:	50.73"
	Season to date average:	51.40"
	% to year to date average:	98.71%

#### Flow Report Notes:

- The *Highest Recorded Aquifer Level* represents a rough average of the highest levels measured in the aquifer during spring melt period.
- The *Lowest Recorded Aquifer Level* is the lowest level recorded in the aquifer at 6,174.0 feet above mean sea level on October 5, 2001. This level is not necessarily indicative of the total capacity of the aquifer.
- The *Creek Bed Elevation* (per Kenneth Loy, West Yost Associates) near Well 2 is 6,186.9 feet.
- *Precipitation Season Total* is calculated from October 2024 through September 2025.
- The true *Season to date Average* could be higher or lower than the reported value due to the uncertainty of the Old Fire Station precipitation measurement during the period 1994 to 2004.
- In October 2011 the data acquisition point for the aquifer was changed from Well 2 to Well 2R.

#### Leaks and Repairs

##### Water

- The District issued three leak/high usage notifications.
- Responded to two after-hours customer service calls.

##### Sewer

- Responded to zero after-hours customer service calls.

#### Vehicles and Equipment

##### Vehicles

- Cleaned vehicles and checked inventory.

##### Equipment

- Cleaned equipment.

#### Operations and Maintenance Projects

##### 1810 Olympic Valley Road (Old Fire Station)

- Inspected and tested the generator.
- General housekeeping.

##### 305 Olympic Valley Road (Administration and Fire Station Building)

- Inspected and tested the generator.

#### Water System Maintenance

- Three bacteriological tests were taken in June: one at 1810 Olympic Valley Road, one at Everline Resort and one at Zone 3 Booster Station; All three samples were reported absent.
- Leak detection services performed: Four.
- Customer service turn water service on: Zero.
- Customer service turn water service off: Two.
- Responded to customer service calls with no water: One

#### Sewer System Maintenance

- Check for I and I issues.
- Sewer cleaning.

#### Telemetry

- The rainfall measurements for the month of June were as follows: Nova Lynx 0.34", Palisades Tahoe Snotel: 0.4".

#### Administration

- Monthly California State Water Boards report.
- Consumer Confidence Report Certified.
- Cross Connection Control Plan Submitted

#### Services Rendered

- |  |      |
|--|------|
| • Underground Service Alerts             | (12) |
| • Pre-remodel inspections                | (0)  |
| • Final inspections                      | (0)  |
| • Fixture count inspections              | (0)  |
| • Water service line inspections         | (0)  |
| • Sewer service line pressure test       | (0)  |
| • Sewer service line inspections         | (0)  |
| • Sewer main line inspections            | (0)  |
| • Water quality complaint investigations | (0)  |
| • Water Backflow Inspections             | (0)  |
| • FOG inspections                        | (0)  |
| • Second Unit inspection                 | (0)  |

#### Other Items of Interest

- Leak detection was completed in all of Zone 2

**ATTACHMENTS:** Monthly Water Audit Report

**DATE PREPARED:** July 18, 2025

## Olympic Valley Public Service District - Monthly Water Audit Report

Audit Month: June  
Year: 2025

Report Date: July 29, 2025

Performed By: Nicolas Massetani

Meter Reader: Jason McGathey

Reading begin Date & Time: 7/1/25 8:00 AM

Reading end Date & Time: 7/1/25 11:00 AM

Total lag time: 3:00:00

Begin Audit Period: 6/2/25 12:00 AM

End Audit Period: 7/1/25 12:00 AM

---

Total Metered Consumption for audit period specified (including hydrant meters): 9,759,249

### Additional Consumption - Unmetered

Fire Department Use: 10,000

Hydrant Flushing: 620,000

Blow-Off Flushing:                     

Sewer Cleaning: 5,000

Street Cleaning:                     

Well Flushing:                     

Tank Overflows:                     

Unread Meter Estimated Reads: 1,993,600

Other:                     

Total Unmetered Consumption (for audit period specified): 2,628,600

### Estimated Unknown Loss - Unmetered

Known Theft:                     

Known Illegal Connections:                     

Total Estimated leaks that have been repaired:                     

Total Estimated Unmetered (for audit period specified):                     

---

Total Production for audit period specified: 13,215,196

Total Metered/Unmetered Consumption for audit period specified: 12,387,849

**Total Water Loss (Production - Consumption): 827,347**

---

**Comments:** The production totals are different than the monthly report due to a different time frame being used. Hydrant flushing and valve turning was completed in June. Leak detection was completed for all of zone 2.

---

---

---

\* Note - All Production & Consumption Totals In U.S. Gallons \*