



OLYMPIC VALLEY PUBLIC SERVICE DISTRICT BOARD REPORT




SUBJECT: November Water & Sewer Operations Report	EXHIBIT: G-2, 5 Pages
AUTHOR: Nicolas Massetani, Operations Superintendent	MEETING DATE: December 16, 2025

RECOMMENDED ACTION: This report is informational only; no action is requested from the Board.

DISCUSSION: This report provides information from the District's management on current projects and activities that are not the subject of a separate report. This report is prepared to provide new information and recent progress only.


Flow Report – November 2025

Water Production:	4.33 MG
Comparison:	0.17 MG more than 2024



Sewer Collection:
Comparison:

3.91 MG
0.45 MG more than 2024



Aquifer Level:

November 30, 2025:
November 30, 2024:
Highest Recorded:
Lowest Recorded:

6,186.8'
6,186.5'
6,192.0'
6,174.0'

Creek Bed Elevation, Well 2:

6,186.9'

Precipitation:

November 2025:
Season to date total:
Season to date average:
% to year to date average:

6.94"
9.84"
9.84"
100.01%

- Flow Report Notes:
- The *Highest Recorded Aquifer Level* represents a rough average of the highest levels measured in the aquifer during spring melt period.
 - The *Lowest Recorded Aquifer Level* is the lowest level recorded in the aquifer at 6,174.0 feet above mean sea level on October 5, 2001. This level is not necessarily indicative of the total capacity of the aquifer.
 - The *Creek Bed Elevation* (per Kenneth Loy, West Yost Associates) near Well 2 is 6,186.9 feet.

- *Precipitation Season Total* is calculated from October 2025 through September 2026.
- The true *Season to date Average* could be higher or lower than the reported value due to the uncertainty of the Old Fire Station precipitation measurement during the period 1994 to 2004.
- In October 2011 the data acquisition point for the aquifer was changed from Well 2 to Well 2R.

Leaks and Repairs

Water

- The District issued two leak/high usage notifications.
- Responded to one after-hours customer service calls.

Sewer

- Responded to zero after-hours customer service calls.

Vehicles and Equipment

Vehicles

- Cleaned vehicles and checked inventory.

Equipment

- Cleaned equipment.

Operations and Maintenance Projects

1810 Olympic Valley Road (Old Fire Station)

- Inspected and tested the generator.
- General housekeeping.

305 Olympic Valley Road (Administration and Fire Station Building)

- Inspected and tested the generator.

Water System Maintenance

- Three bacteriological tests were taken in September: one at 1810 Olympic Valley Road, one at Everline Resort and one at Zone 3 Booster Station; All three samples were reported absent.
- Leak detection services performed: Zero.
- Customer service turn water service on: Zero.
- Customer service turn water service off: Zero.
- Responded to customer service calls with no water: One
- Water meter upgrades: Twenty Eight

Sewer System Maintenance

- Check for I and I issues.
- Sewer cleaning.

Telemetry

- The rainfall measurements for the month of August were as follows:
Nova Lynx: 6.94", Palisades Tahoe Snotel: 6.3".

Administration

- Monthly California State Water Boards report.

Services Rendered

- Underground Service Alerts (7)
- Sewer service line inspections (1)
- Sewer service line pressure tests (4)
- Manhole Vacuum Test (1)
- Water service line inspections (0)
- Water and Sewer Final Inspection (3)
- Water quality complaint investigations (0)

Other Items of Interest

- Fall flushing of dead-ends complete and chlorine injection has stopped.

ATTACHMENTS: Monthly Water Audit Report

DATE PREPARED: December 5, 2025

Olympic Valley Public Service District - Monthly Water Audit Report

Audit Month: November Report Date: December 5, 2025 Performed By: Nic Massetani
Year: 2025
Meter Reader: Ben Procida Reading begin Date & Time: 12/2/25 12:00 AM
Reading end Date & Time: 12/3/25 12:00 PM
Total lag time: 36:00:00
Begin Audit Period: 10/30/25 12:00 AM
End Audit Period: 12/2/25 12:00 AM

Total Metered Consumption for audit period specified (including hydrant meters): 3,002,200

Additional Consumption - Unmetered
Fire Department Use: 5,000
Hydrant Flushing: 403,005
Blow-Off Flushing: 134,375
Sewer Cleaning: _____
Street Cleaning: _____
Well Flushing: _____
Tank Overflows: _____
Unread Meter Estimated Reads: 9,295
Other: _____
Total Unmetered Consumption (for audit period specified): 551,675

Estimated Unknown Loss - Unmetered
Known Theft: _____
Known Illegal Connections: _____
Total Estimated leaks that have been repaired: 100,800
Total Estimated Unmetered (for audit period specified): 100,800

Total Production for audit period specified: 4,733,558

Total Metered/Unmetered Consumption for audit period specified: 3,654,675

Total Water Loss (Production - Consumption): 1,078,883

Comments: The production totals differ from the monthly report due to a different time frame being used. The District continues active leak detection efforts and recently located a 5 GPM leak, which was repaired on Rock Garden Ct. Additionally, multiple commercial meters were installed in November for several of our high-use customers. There is typically a delay before their meter reads are fully uploaded into the system.

* Note - All Production & Consumption Totals In U.S. Gallons *